



**GOVT. OF ASSAM  
OFFICE OF THE DIRECTOR,  
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI**

15  
MAY 2020

RULE - 18(2)

No. F&ES/FPW/20/63/20  
To:

E.O.R.M. (S)

Dated Guwahati the 26/03/2020

The Principal,  
S.K. Roy Memorial Institute &  
Education (B.Ed. College),  
Katlicherra, Dist:- Hailakandi, Assam.

**RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE S.K. ROY MEMORIAL INSTITUTE AT EDUCATION ( B.ED. COLLEGE), KATLICHERRA, DIST:- HAILEAKANDI, ASSAM.**

With reference to your completion report under No. NIL Dated 25.02.2020 and on the basis of the inspection report submitted by Station Officer, Sanjoy Singh on the building as per description below at Dag No. 14, 440 Patta No. 18, 442 Mouza (Place- Katlicherra, Hailakandi) in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention means of escape measures as declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of B.ED. COLLEGE subject to condition mentioned overleaf.

**DETAILS OF APPROVED OCCUPATION-**

**GROUND FLOOR**

1. Floor area - 1500 ft<sup>2</sup> / sq.mt.

**FIRST FLOOR**

1. Floor area - 500 ft<sup>2</sup> / sq.mt.

1. Purpose of utilization :-

*For Educational Purpose.*

2. Purpose of utilization :-

*For Educational Purpose.*

**Details of Fire Fighting measures found in working condition;**

1. Hose Reel Hose system
2. Manually Operated Electric Fire Alarm system
3. Fire Extinguishers- 10 Nos.
4. Terrace Water Tank
5. Terrace Pump

*S/No 03/2020*

Deputy Director,  
for and on behalf of  
Director of Fire and Emergency Services,  
Assam, Guwahati

NO. F&ES/FPW/

Copy to :-

Dated Guwahati the .

1. The Deputy Commissioner, Hailakandi, Assam for information and necessary action.
2. The Chairman, Hailakandi Municipal Board, Assam for information and necessary action.
3. The Station Officer, Katlicherra F&ES Station, for information.

Deputy Director,  
for and on behalf of  
Director of Fire and Emergency Services,  
Assam, Guwahati

(( 2 ))

**CONDITION -**

1. The N.O.C. is valid up to: - **31.03.2021**.
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.  
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

Deputy Director,  
for and on behalf of  
Director of Fire and Emergency Services,  
**J. Assam, Guwahati**